




A1	Main Switch BREMAS DS0323BFCD 3x 32A - 500V
TR	Safety Isolating Trasformer 50 VA 400 - 24 V
K04	Contactor LC1 D18 B7 40 A
K10 - K08	Relay FINDER 40.52 250 V - 5 A
RE	Heating EEx d 8 KW - 400 V
LA	Warning light alarm MIN water temperature
LV	Warning light Heating ON
LR	Warning light Heating OFF
F01	Automatic miniature Circuit Breaker ABB 203 C25 3x25A
SR	Warning light alarm MAX water temperature
F10	Switch fuse carrier LEGRAND 05808 (10 x 38) 1 A
K09	Holding relay with double coil OMRON MY2K 24V AC - 5 A
PR1	Electronic Thermostat PR 4131 - work temperature regulation (75 ° C degree)
PR2	Electronic Thermostat PR 4131 - Min and Max temperature regulation (50° and 96° degree cutoff)
F05 - F05	Switch Fuse carrier LEGRAND 05828 (10 x 38) 1 A
PS	Release button for reset max temperature locked
F051	Switch Fuse carrier LEGRAND 37181 (5 x 20)
R1	Modular interface EMR Finder 38.51.7 - 24 v - 6A

COPRIM

ALTAVILLA - VI -

0444-349091 fax 349084

QUADRO COMANDO VAPORIZZATORE 100 KG/h Ex d - 16Kw-400V

Comand Box for electric vaporizer Ex d - 100Kg/h -16 Kw -400 v

data 22/05/15

schema

1.06.3105

rev.

diseg.